

SUPERVISOR'S USE ONLY

1Draw a cross through the box (☒)
if you have NOT written in this booklet

+

90939

909390

**Mana Tohu Mātauranga o Aotearoa**
New Zealand Qualifications Authority

Level 1 Physics 2023

90939 Demonstrate understanding of aspects of heat

Credits: Four

Achievement	Achievement with Merit	Achievement with Excellence
Demonstrate understanding of aspects of heat.	Demonstrate in-depth understanding of aspects of heat.	Demonstrate comprehensive understanding of aspects of heat.

Check that the National Student Number (NSN) on your admission slip is the same as the number at the top of this page.

You should attempt ALL the questions in this booklet.

Make sure that you have Resource Sheet L1–PHYSR.

In your answers use clear numerical working, words, and/or diagrams as required.

Numerical answers should be given with an appropriate SI unit.

If you need more room for any answer, use the extra space provided at the back of this booklet.

Check that this booklet has pages 2–12 in the correct order and that none of these pages is blank.

Do not write in any cross-hatched area (DO NOT WRITE). This area will be cut off when the booklet is marked.

YOU MUST HAND THIS BOOKLET TO THE SUPERVISOR AT THE END OF THE EXAMINATION.

- (c) The heat output of a server is often measured in British Thermal Units (BTU) per hour. One BTU is the amount of energy required to raise the temperature of one pound of water (0.454 kg) by one degree Fahrenheit (0.556 °C).

Calculate the amount of energy in one BTU.

State your answer in Joules.

The specific heat capacity of water is $4182 \text{ J kg}^{-1} \text{ }^\circ\text{C}^{-1}$.

- (d) The hot air is cooled down by CRACs. These require energy to run.

One server produces 34.5 MJ ($34.5 \times 10^6 \text{ J}$) of heat in 24 hours. Running the CRACs requires an **additional** amount of electric energy that equals 89% of the power that the servers produce as heat.

Calculate the **total power** required by a data centre that runs **25 000 servers**.

QUESTION TWO: IMMERSION COOLING

Some data centres use ‘immersion cooling’ methods to help cool their servers. For these methods, the computers are submerged in a tank of liquid coolant. A system of pumps draws the warm liquid coolant out and replaces it with cool liquid.



Source: <https://www.akcp.com/blog/liquid-cooling-data-centers/>

- (a) Define the term ‘specific heat capacity’.

A particular server rack contains 64 servers of 250 W each. The rack is submerged in a tank of 967 kg of liquid coolant. This liquid coolant has a specific heat capacity of $1100 \text{ J kg}^{-1} \text{ }^\circ\text{C}^{-1}$.

- (b) Show that the temperature of the liquid coolant increases by $0.90 \text{ }^\circ\text{C}$ every minute if no liquid is replaced.


QUESTION THREE: TWO-PHASE COOLING

‘Two-phase cooling’ systems are a variant of immersion cooling. The difference is that the liquid two-phase coolant is allowed to evaporate. The warm vapour is carried away, condensed back to the liquid, cooled, and re-supplied to the system.



Source: <https://images.anandtech.com/doci/15122/IMG4762.jpg>

The heating curve of a particular two-phase coolant is shown below, where the coolant was heated at a constant rate.



- (a) Using information from the heating curve, determine the boiling point of the two-phase coolant.

Question Three continues
on the next page.

